



Ascention Assets  
23 Boydell Street, Kenwick WA 6107  
PO Box 849, Cannington WA 6987  
O +61 8 9267 2343 F +61 8 9452 1343  
[info@ascention.com.au](mailto:info@ascention.com.au)  
[www.ascention.com.au](http://www.ascention.com.au)

### Generator Inspection Check List

Date: \_\_\_\_\_

Generator Location: \_\_\_\_\_

Generator Serial #: \_\_\_\_\_

Inspected By (Please Print) \_\_\_\_\_

#### Check List:

1. Check generator for overall condition (loose or missing parts, open or missing panels, loose wiring, etc.). Describe any problem conditions below.

2. Are there any leaks? Yes \_\_\_\_\_ No \_\_\_\_\_

3. Cooling system coolant level normal? Yes \_\_\_\_\_ No \_\_\_\_\_

4. Oil level normal? Yes \_\_\_\_\_ No \_\_\_\_\_

5. Battery condition, wire connections, acid leaks, and electrolyte levels? Ok \_\_\_\_\_ No \_\_\_\_\_

6. Fan belts and other drive belts in good condition and with proper tension? Yes \_\_\_\_\_ No \_\_\_\_\_

7. Meter Reading? \_\_\_\_\_

#### Comments:

Please note damages and please support notes with photos.

#### NOTES:

1. \_\_\_\_\_

Inspected on behalf of the hirer

Name; \_\_\_\_\_

Signature; \_\_\_\_\_

Date; \_\_\_\_\_